
From: Lisa Moeller
Sent: Thursday, August 10, 2017 6:26 PM
To: Department Heads; City Council; PD ALL; Karla Flaming
Subject: Power Fully Restored 18:25 hrs

Power is now fully restored to all Blaine City Light customers.

Sent with Good (www.good.com)

From: Lisa Moeller
Sent: Thursday, August 10, 2017 5:06 PM
To: Mike Haslip; Department Heads; PD ALL; Bob Crider; City Council
Cc: 'LUNA, MICHAEL K'; 'MCMANUS, MICHAEL J'; Karla Flaming
Subject: 17:00hr Update on power outage

Blaine City Light advises power has been restored to the Crest Dr. neighborhood. The only two customers now without power are the Border Patrol Station on H Street and Border Brew. The crew is on scene there now, and I've been told they hope to have power fully restored in the next 30 to 60 minutes.

Lisa Moeller

-----Original Message-----

From: Lisa Moeller
Sent: Thursday, August 10, 2017 15:34
To: Mike Haslip; Department Heads; PD ALL; Bob Crider
Cc: 'LUNA, MICHAEL K'; 'MCMANUS, MICHAEL J'; Karla Flaming
Subject: 15:30hr Update on power outage

Blaine City Light advises power is back on to all customers except the original outage area on Crest Dr. and the Border Patrol Station on H Street and their neighbors at Border Brew. Once power is restored to the Crest Dr. neighborhood they will then be searching for and replacing a bad line on H Street.

Lisa Moeller

-----Original Message-----

From: Mike Haslip
Sent: Thursday, August 10, 2017 13:14
To: Department Heads; PD ALL; Bob Crider
Cc: 'LUNA, MICHAEL K'; 'MCMANUS, MICHAEL J'
Subject: 13:00hr Update on power outage

FYI

Blaine City Light is working to restore power to an area from just west of Sr543 to Vista Terrace, and from about Boblett St to the border. A small outage about 930am in the Crest Drive neighborhood expanded to the currently affected area, but the cause of the cascade failure has not been determined. The City Light team is in the field diagnosing and hopes to start bringing segments of affected homes and businesses back online in the next hour. The City Water Dept well field on Pipeline Is offline, and BBWSD has been asked to reduce their draw from the system until our well field is re-energized.

Emails sent to and from this address are subject to public disclosure.